

USE & CARE INSTRUCTIONS

Congratulations on your purchase of **De'Longhi radiators designed to** give years of heating comfort pleasure. Please read these suggestions carefully to ensure that warranty is valid.

25 YEAR WARRANTY

Your De'Longhi radiator is warranted to be free of defects in material and workmanship, under normal household use, for a period of 25 years. This warranty excludes damage caused by accident, misuse or abuse.

All De'Longhi radiators are produced from the highest quality deep pressing steel and steel tubes. They are tested according to the EN442 European norm and the production runs under an ISO9001:2008 quality system, subjected to internal controls and Independent audits by external quality marks. This ensures that all De'Longhi radiators can withstand the stresses and conditions to which a radiator is normally subjected to in the lifetime of a heating system, which is normally 25 to 30 years.

The maximum operating pressure depends on the product range (see catalogues for more information). The maximum operating temperature is generally 110°C, specific products may have a reduced operating temperature range (see catalogue).

Panels and column radiators are painted and protected from corrosion by a three step process.

- Degreasing and zinc phosphating
- Cathodic electroplating
- Epoxy powder coat finish

De'Longhi offers on its panels and column radiators a;

25 year functional guarantee

provided that the installation has been installed by an appropriately qualified person. In particular, De'Longhi Radiators cannot acknowledge claims due to:

- Damage to radiators stocked in uncovered areas
- Damage due to transportation, handling, incorrect installation, external agents, overpressure or frost
- Radiators connected either to the sanitary system or to systems with open expansion vessels
- Damage to radiators placed in aggressive environments, such as pools, showers, bathrooms, saunas, public toilets etc.

On completion of installation, the system must be properly flushed and filled with an approved corrosion inhibitor (i.e. Fernox). Corrosion inhibitors must be checked at regular intervals and concentration levels verified and recorded by a qualified installer (this can be done during your annual boiler/system service). Failure to observe this procedure will render this guarantee invalid.



18/01/10

1361000GDL/11.10